

REPORT No 11658

Date of issue: March 28, 2026

Status: FINAL REPORT

ASTM D93

FLASH POINT BY PENSKEY-MARTENS CLOSED CUP TESTER

Program: SQ-1554.V2

This document is issued by the Company subject to its Terms and Conditions, available on request or accessible at <https://www.ptsouthquality.com/terms-and-conditions>. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Copyright © 2024 South Quality, Buenos Aires, ARGENTINA



Prepared by:	Reviewed by:	Approved by:
Mateo Giovanni Assistant Technician	Eng. Erika Brest Chemistry expert	Eng. Emiliano Medina Quality Assurance Lead

TABLE OF CONTENTS

1. FOREWORD	3
2. ORGANIZATION	3
3. OBJECTIVE	3
4. PARTICIPANT	3
5. HOMOGENEITY	4
6. SAMPLE INFORMATION	5
7. IMAGES	5
8. ASSIGNED VALUES	6
9. PARTICIPANT RESULTS	6
10. STATISTICS	6
11. EVALUATION OF PERFORMANCE	7
12. CONCLUSIONS	7
APPENDICES	
APPENDIX A - INSTRUCTIONS	8
APPENDIX B - PARTICIPANT RESULTS (TR # PT1-CHM26-HL)	11

1. FOREWORD

This report summarizes the results of the **SQ-1554.V2** proficiency testing program on the determination of the flash point of petroleum products. This program is conducted in a bilateral format, following the A.3.3 classification of the ISO 17043 standard ("Split-sample testing schemes").

South Quality conducted the testing program in February 2026 with the aim of assessing the laboratory's ability to competently perform the designated tests.

2. ORGANIZATION

Program Coordinator: Eng. Erika Brest
 Assistant Technician: Mateo Giovanni
 Statistic: Lic. Manuel Tozaki
 Supervision: Eng. Emiliano Medina

3. OBJECTIVE

The objective of this proficiency testing program is to determine the corrected flash point, using the following standard:

Standard
ASTM D93 - 25

To verify this, batches of petroleum-derived lubricating oils have been selected.

Participants in this program have not been previously informed about the expected behavior of the samples they receive.

4. PARTICIPANT

Company: **TÜV SÜD PSB Pte Ltd**
 Laboratory: **Elemental Analysis Lab**
 Country: Singapore
 Client ID: S333
 Contact person: Dr. Songbai Tang
 Product Manager
songbai.tang@tuvsud.com

5. HOMOGENEITY

Several batches were prepared identically by the staff at South Quality.

Subsequently, a homogeneity study was conducted with an ISO 17025 accredited laboratory.

The control process followed ISO 33405: 2024, clauses 7.4.1.1 / 7.4.1.2. Stratified random sampling was applied, and samples were selected using random number generation software.

The results of this test are presented below:

Size of each batch: **50 units**

Tested samples from each batch: **5 units**

DETERMINATION	HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES		
	BATCH: LCH3240	BATCH: LCH3241	BATCH: LCH3242
Corrected flash point	YES	NO	YES

Size of each batch: **50 units**

Tested samples from each batch: **5 units**

DETERMINATION	HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES		
	BATCH: LCH3258	BATCH: LCH3259	BATCH: LCH3260
Corrected flash point	YES	YES	YES

Samples for this program are taken from the selected batches identified as **LCH3240** and **LCH3259**.

For the indicated batches, the values determined in the homogeneity study are utilized as the assigned values.

The analysis of the test data indicated that the selected samples exhibited sufficient homogeneity for the program. Therefore, the results of participants identified as outliers cannot be attributed to sample variability.

6. SAMPLE INFORMATION

The following samples were sent for testing:

Batch:	LCH3240
Sample ID:	05
Characteristics:	Mineral oil - 250ml

Batch:	LCH3259
Sample ID:	02
Characteristics:	Synthetic oil - 250ml

7. IMAGES



8. ASSIGNED VALUES

BATCH	FLASH POINT - AVG	
	(°C)	SD
LCH3240	215.2	0.89
LCH3259	94.3	0.98

9. PARTICIPANT RESULTS (SEE APPENDIX B)

CODE	FLASH POINT - AVG (°C)
LCH3240-05	214.5
LCH3259-02	93.5

10. STATISTICS

The results must be treated as quantitative.

The comparison is made according to B.3.1.3 of ISO 17043 and the appropriate technique is to compare participant results with the assigned values. The results can be compared using percent difference ***z score***.

$$z = \frac{x - X}{\hat{\sigma}}$$

x is the participant's result

X is the assigned value

$\hat{\sigma}$ is the standard deviation

The performance evaluation of each sample is carried out with the following criteria:

$|z| \leq 2.0$ indicates “satisfactory” performance and generates no signal;

$2.0 < |z| < 3.0$ indicates “questionable” performance and generates a warning signal;

$|z| \geq 3.0$ indicates “unsatisfactory” performance and generates an action signal;

11. EVALUATION OF PERFORMANCE

BATCH	FLASH POINT - AVG (°C)		z score	PERFORMANCE RESULT
	PARTICIPANT RESULT	ASSIGNED VALUE		
LCH3240	214.5	215.2	0.79	SATISFACTORY
LCH3259	93.5	94.3	0.82	SATISFACTORY

12. CONCLUSIONS

The overall performance on this **SQ-1554.V2** program from the participant laboratory **TÜV SÜD PSB Pte Ltd - Elemental Analysis Lab**, is **SUFFICIENT** based on expected results.

The criteria used for evaluating the overall performance are as follows:

- **SUFFICIENT** performance: No unsatisfactory/questionable results were obtained.
- **ALMOST SUFFICIENT** performance: No unsatisfactory results were obtained, but one questionable result was found.
- **INSUFFICIENT** performance: An unsatisfactory result or two questionable results were obtained.

APPENDIX A

INSTRUCTIONS



INSTRUCTIONS

PROGRAM:	Flash point by pensky-martens closed cup tester
CODE:	SQ-1554
VERSION:	2
STANDARD:	ASTM D93
COORDINATOR:	Eng. Erika Brest (ebrest@ptsouthquality.com)

1 - General

This document serves as a guide for managing the results of the **SQ-1554.V2** program.

2 - Standard

ASTM D93 - 25

3 - Tests involved

TEST
Determination of the flash point of a petroleum product (Corrected flash point)

4 - Samples

CODE	SAMPLE	QUANTITY
LCH3240-05	Mineral oil	250 ml
LCH3259-02	Synthetic oil	250 ml

5 - Notes

- a) Being a bilateral program, there is no deadline for submitting results.
- b) The participant must submit the results using the usual report employed by their laboratory.
- c) The samples are to be handled as routine lab samples, with all testing, documentation, and reporting adhering to ASTM D93 (Procedure A).
- d) Samples must be retained until the end of the program, which concludes with the submission of the final report.
- e) To review the results, test images would be appreciated. Images can be attached at the end of this document or sent by email.

PHOTOGRAPHS

DSQ-012

- REV 06 -

SQ-1554.V2

3 de 3

APPENDIX B

PARTICIPANT RESULTS (TEST REPORT # PT1-CHM26-HL)

Test Report No. PT1-CHM26-HL

Date: 06 FEB 2026 Email: songbai.tang@tuvsud.com

Client's Ref:

Note: This report is issued subject to the Testing, Certification, Validation and Verification Regulations (TCVVR) of the TUV SUD Group and the General Terms and Conditions of Business of TUV SUD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.



Add value.
Inspire trust.

SUBJECT

Flash point analysis of petroleum products in accordance with ASTM D3278-21

CLIENT

PT Test supplied by South Quality

SAMPLE SUBMISSION / TEST DATE

19 JAN 2026 / 28-29 JAN 2026

DESCRIPTION OF SAMPLE

Two samples as below were received for Bilateral PT Scheme, SQ-1554.V2 (Client S333).



Sample 1:

Sample ID: 02
Sample Name: ELAION MOTO 2T
Batch: LCH3259

Sample 2:

Sample ID: 05
Sample Name: ELAION MI 2050
Batch: LCH3240



Laboratory:
TUV SUD PSB Pte. Ltd.
15 International Business Park
TUV SUD @ IBP
Singapore 609937

Phone: +65-6778 7777
E-mail: info.sg@tuvsud.com
<https://www.tuvsud.com/sg>
Co. Reg: 199002957R

Regional Head Office:
TUV SUD Asia Pacific Pte. Ltd.
15 International Business Park
TUV SUD @ IBP
Singapore 609937
TUV®

Page 1 of 3

Test Report No. PT1-CHM26-HL
06 FEB 2026



METHOD OF TEST

ASTM D3278-21: Standard Test Methods for Flash Point of Liquids by Small Scale Closed-Cup Apparatus.

(Note: The lab facility and accredited method is ASTM D3278-21. No facility for standard ASTM D93-25: Standard Test Methods for Flash Point by Pensky-Martens Closed Cup Tester. The participating lab Just uses the same PT samples to do the rest, in accordance with standard ASTM D3278-21, as indicated during enquiry of registration. It is expected the test results of same samples are close to each other although different standards and instrument. The participating lab understands the test results will be compared to known flash point values, in accordance with ASTM D93-25.)

RESULTS

Table 1. Flash point results of the samples.

Sample Names	Test 1 (°C)	Test 2 (°C)	Test 3 (°C)	Average (°C)	Uncertainty (°C)
Sample ID: 02 Sample Name: ELAION MOTO 2T Batch: LCH3259	93.5	93.5	94.0	93.5	0.5
Sample ID: 05 Sample Name: ELAION MI 2050 Batch: LCH3240	214.5	214.5	214.5	214.5	1.0

Note: Temperature resolution of the instrument: 0.5 °C.



MS TAN HUI LIN
CHEMIST
ELEMENTAL ANALYSIS
CHEMICAL CENTRE



DR TANG SONGBAI
PRODUCT MANAGER
ELEMENTAL ANALYSIS
CHEMICAL CENTRE

Test Report No. PT1-CHM26-HL
06 FEB 2026



Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, 15 International Business Park TÜV SÜD @ IBP Singapore 609937.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing, Certification, Validation and Verification Regulations (TCVVR) of the TÜV SÜD Group.

Effective 27 March 2024



----- END OF REPORT -----