

REPORT No 11665

Date of issue: May 4, 2026

Status: FINAL REPORT

HEALTH TECHNICAL MEMORANDUM 04-01 SUPPLEMENT PERFORMANCE SPECIFICATION D 08: THERMOSTATIC MIXING VALVES (HEALTHCARE PREMISES) Program: SQ-6045

This document is issued by the Company subject to its Terms and Conditions, available on request or accessible at <https://www.ptsouthquality.com/terms-and-conditions>. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Copyright © 2024 South Quality, Buenos Aires, ARGENTINA



Prepared by:	Reviewed by:	Approved by:
Berenice Ferrel Assistant Technician	Lic. Esther Casas Physics expert	Eng. Emiliano Medina Quality Assurance Lead

TABLE OF CONTENTS

1. FOREWORD	3
2. ORGANIZATION	3
3. OBJECTIVE	3
4. PARTICIPANT	3
5. HOMOGENEITY	4
6. SAMPLE INFORMATION	5
7. IMAGES	5
8. ASSIGNED VALUES	6
9. PARTICIPANT RESULTS	7
10. STATISTICS	8
11. EVALUATION OF PERFORMANCE	8
12. CONCLUSIONS	9
APPENDICES	
APPENDIX A - INSTRUCTIONS	10
APPENDIX B - PARTICIPANT RESULTS (TEST REPORT)	13

1. FOREWORD

This report summarizes the results of the **SQ-6045** proficiency testing program on the determination of compliance with the general requirements. This program carried out in a bilateral format, following the “split-sample” design described in clause A.4.2 of ISO/IEC 17043: 2023 (Alternative interlaboratory comparisons).

South Quality conducted the testing program in February 2026 with the aim of assessing the laboratory's ability to competently perform the designated tests.

2. ORGANIZATION

Program Coordinator: Lic. Esther Casas
 Assistant Technician: Berenice Ferrel
 Statistic: Lic. Manuel Tozaki
 Supervision: Eng. Emiliano Medina

3. OBJECTIVE

The objective of this proficiency testing program is to determine verification of compliance with the performance, material requirements and test methods for thermostatic mixing valves for use in healthcare premises, using the following standard:

Standard
Health Technical Memorandum 04-01 - 2017

To verify this, batches of thermostatic mixing valve samples have been selected.

Participants in this program have not been previously informed about the expected behavior of the samples they receive.

4. PARTICIPANT

Company: **Kiwa Netherlands**
 Laboratory: **Drinking water laboratory**
 Country: The Netherlands
 Client ID: E510
 Contact person: Mitchell Burgwal
 Laboratory coordinator
mitchell.burgwal@kiwa.com

5. HOMOGENEITY

Several batches were prepared identically by the staff at South Quality.

Subsequently, a homogeneity study was conducted with an ISO/IEC 17025 accredited laboratory.

The control process followed ISO 33405: 2024, clauses 7.4.1.1 / 7.4.1.2. Stratified random sampling was applied, and samples were selected using random number generation software.

The results of this test are presented below:

Size of each batch: **250 units**

Tested samples from each batch: **25 units**

HTM 04-01 CLAUSE No	HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES		
	BATCH: LMI2792	BATCH: LMI2793	BATCH: LMI2794
5.4	YES	YES	YES
5.5	YES	YES	YES
5.6	YES	YES	YES
5.7	NA	NA	NA
5.8	NA	NA	NA
6.1	NA	NA	NA
6.2	NA	NA	NA
6.3	YES	YES	YES
7.3	YES	YES	YES
7.5	NA	NA	NA
7.6	NA	NA	NA
7.7	YES	YES	YES
7.8	NA	NA	NA
7.9	YES	YES	YES
7.10	YES	YES	YES
7.11	YES	YES	YES
7.12	YES	NO	YES
8.0	YES	YES	YES
9.0	YES	YES	YES
10.0	YES	YES	YES

Samples for this program are taken from the selected batch identified as **LMI2792**.

For the indicated batch, the values determined in the homogeneity study are utilized as the assigned values.


The analysis of the test data indicated that the selected samples exhibited sufficient homogeneity for the program. Therefore, the results of participants identified as outliers cannot be attributed to sample variability.

6. SAMPLE INFORMATION

The following samples were sent for testing:

Batch:	LMI2792
Sample ID:	08
Characteristics:	Thermostatic mixing valve - 5 units

7. IMAGES



8. ASSIGNED VALUES

BATCH: LMI2792		
CLAUSE	REQUIREMENT	VERDICT
5.4	Leaktightness of the thermostatic mixing valve upstream of the obturator and of the obturator	PASS
5.5	Leaktightness of the obturator of the thermostatic mixing valve: cross flow between hot and cold water	PASS
5.6	Leaktightness of the thermostatic mixing valve downstream of the obturator	PASS
5.7	Leaktightness of the manual diverter of the thermostatic mixing valve	N/A
5.8	Leaktightness of the diverter with automatic return of the thermostatic mixing valve	N/A
6.1	Durability of on/off (flow) control	N/A
6.2	Durability of diverters	N/A
6.3	Durability of thermostat	PASS
7.3	Flow rate and sensitivity of temperature control	PASS
7.5	Mixed water temperature overshoot on operation of diverter (manual or automatic return)	N/A
7.6	Mixed water temperature overshoot on operation of second outlet	N/A
7.7	Mixed water temperature overshoot on starting from ambient	PASS
7.8	Mixed water temperature overshoot on adjustment of mixed water temperature	N/A
7.9	Thermal shut-off	FAIL
7.10	Temperature stability with changing water supply pressure	FAIL
7.11	Temperature stability with changing water supply temperature	PASS
7.12	Temperature stability at reduced flow rate	FAIL

9. PARTICIPANT RESULTS (SEE APPENDIX B)

CODE: LMI2792-08		
CLAUSE	REQUIREMENT	VERDICT
5.4	Leaktightness of the thermostatic mixing valve upstream of the obturator and of the obturator	PASS
5.5	Leaktightness of the obturator of the thermostatic mixing valve: cross flow between hot and cold water	PASS
5.6	Leaktightness of the thermostatic mixing valve downstream of the obturator	PASS
5.7	Leaktightness of the manual diverter of the thermostatic mixing valve	N/A
5.8	Leaktightness of the diverter with automatic return of the thermostatic mixing valve	N/A
6.1	Durability of on/off (flow) control	N/A
6.2	Durability of diverters	N/A
6.3	Durability of thermostat	PASS
7.3	Flow rate and sensitivity of temperature control	PASS
7.5	Mixed water temperature overshoot on operation of diverter (manual or automatic return)	N/A
7.6	Mixed water temperature overshoot on operation of second outlet	N/A
7.7	Mixed water temperature overshoot on starting from ambient	PASS
7.8	Mixed water temperature overshoot on adjustment of mixed water temperature	N/A
7.9	Thermal shut-off	FAIL
7.10	Temperature stability with changing water supply pressure	FAIL
7.11	Temperature stability with changing water supply temperature	PASS
7.12	Temperature stability at reduced flow rate	FAIL

10. STATISTICS

The results must be treated as qualitative.

For qualitative results, the comparison will be made directly against the assigned values, so any difference will be evaluated as **Unsatisfactory**.

11. EVALUATION OF PERFORMANCE

CLAUSE	REQUIREMENT	BATCH: LMI2792		PERFORMANCE RESULT
		PARTICIPANT RESULT	ASSIGNED VALUE	
5.4	Leaktightness of the thermostatic mixing valve upstream of the obturator and of the obturator	PASS	PASS	SATISFACTORY
5.5	Leaktightness of the obturator of the thermostatic mixing valve: cross flow between hot and cold water	PASS	PASS	SATISFACTORY
5.6	Leaktightness of the thermostatic mixing valve downstream of the obturator	PASS	PASS	SATISFACTORY
5.7	Leaktightness of the manual diverter of the thermostatic mixing valve	N/A	N/A	SATISFACTORY
5.8	Leaktightness of the diverter with automatic return of the thermostatic mixing valve	N/A	N/A	SATISFACTORY
6.1	Durability of on/off (flow) control	N/A	N/A	SATISFACTORY
6.2	Durability of diverters	N/A	N/A	SATISFACTORY
6.3	Durability of thermostat	PASS	PASS	SATISFACTORY
7.3	Flow rate and sensitivity of temperature control	PASS	PASS	SATISFACTORY
7.5	Mixed water temperature overshoot on operation of diverter (manual or automatic return)	N/A	N/A	SATISFACTORY
7.6	Mixed water temperature overshoot on operation of second outlet	N/A	N/A	SATISFACTORY
7.7	Mixed water temperature overshoot on starting from ambient	PASS	PASS	SATISFACTORY
7.8	Mixed water temperature overshoot on adjustment of mixed water temperature	N/A	N/A	SATISFACTORY
7.9	Thermal shut-off	FAIL	FAIL	SATISFACTORY
7.10	Temperature stability with changing water supply pressure	FAIL	FAIL	SATISFACTORY
7.11	Temperature stability with changing water supply temperature	PASS	PASS	SATISFACTORY
7.12	Temperature stability at reduced flow rate	FAIL	FAIL	SATISFACTORY

12. CONCLUSIONS

The overall performance of this **SQ-6045** program from the participant laboratory **KIWA NETHERLANDS - DRINKING WATER LABORATORY**, is **SUFFICIENT** based on expected results.

The criteria used for the evaluation of the overall performance is the following:

- **SUFFICIENT** performance: No unsatisfactory results were obtained.
- **INSUFFICIENT** performance: An unsatisfactory result was obtained.

APPENDIX A

INSTRUCTIONS



INSTRUCTIONS

PROGRAM:	Health Technical Memorandum 04-01: Supplement Performance specification D 08: thermostatic mixing valves (healthcare premises)
CODE:	SQ-6045
VERSION:	-
STANDARD:	Health Technical Memorandum 04-01
COORDINATOR:	Lic. Esther Casas (ecasas@ptsouthquality.com)

1 - General

This document serves as a guide for managing the results of the **SQ-6045** program.

2 - Standard / Method

Health Technical Memorandum 04-01 - 2017

3 - Tests involved

TEST
Verification of compliance with the performance, material requirements and test methods for thermostatic mixing valves for use in healthcare premises (Complete standard - Testing according Fig. 1)

4 - Samples

CODE	SAMPLE	QUANTITY
LMI2792-08	Thermostatic mixing valve	5

5 - Notes

- a) Being a bilateral program, there is no deadline for submitting results.
- b) Five samples are provided for testing. The participant must select three to perform the tests as shown in Figure 1 and keep two in reserve for retesting if needed.
- c) The participant must submit the results using the usual report employed by their laboratory.
- d) Samples must be retained until the end of the program, which concludes with the submission of the final report.
- e) To review the results, test images would be appreciated. Images can be attached at the end of this document or sent by email.

PHOTOGRAPHS

APPENDIX B

PARTICIPANT RESULTS (TEST REPORT)

Page 1 of 22
Order number: XXXXXX
Kiwa report number: XXXXX-TR-rev0



Date of report 27 February 2026

Test report for Thermostatic mixing valves (Healthcare premises) on the basis of NHS D08

Applicant	South Quality		
Manufacturer	South Quality		
Tested products			
Model no.	LMI2792-08	LMI2792-08	LMI2792-08
Designation	Sample A (HP-T44)	Sample B (HP-T44)	Sample C (HP-T44)
Kiwa reference number(s):	A14235		
Date of test	16-09-2025 – 20-02-2026		
Tests performed by	P. Dubbelman, test engineer		
Reference documents	NHS Model engineering specifications - D 08 "Thermostatic mixing valves (Healthcare premises)" -2017 edition		

Authorised by

M. Burgwal
 Lab. Coordinator
 Unit Water & Gas Installations



- This assessment report is the exclusive property of Kiwa Nederland BV.
- This assessment is carried out by Kiwa Nederland BV with accreditation number L015 based on EN-ISO/IEC 17025.
- The assessment results are based on the objects as described in this report.
- This test report contains confidential information and may only be shared in its entirety without any modifications to the content. For sharing a part of the test report permission is needed by Kiwa.
- Activities marked in this report with * are not part of the accredited scope of Kiwa Nederland BV.
- Assessment results provided by the client, which are included in the test report of Kiwa, are clearly marked. These assessment results can affect the validity. The results apply to the sample(s) as received.
- Any opinions or conclusions in this report are not part of the scope of accreditation.



International accredited testing
 laboratory in accordance with
 EN ISO/IEC 17025
 www.rva.nl

Kiwa Nederland BV
 Sir W. Churchilllaan 273 - P.O. Box 70 - 2280 AB Rijswijk - The Netherlands
 Telephone: +31 (0)88 998 4400 - Telefax: +31 88 998 4420 - www.kiwa.nl

The RvA is participant in ILAC MRA

1 Summary of tests

The following test according to the clauses of NHS D08, 2017 edition have been conducted

	Pass	Fail	NPD	N/A
5.4 Leaktightness of the thermostatic mixing valve upstream of the obturator and of the obturator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.5 Leaktightness of the obturator of the thermostatic mixing valve: cross flow between hot end cold water	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.6 Leaktightness of the thermostatic mixing valve downstream of the obturator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.7 Leaktightness of the manual diverter of the thermostatic mixing valve	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.8 Leaktightness of the diverter with automatic return of the thermostatic mixing valve	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6.1 Durability of on/off (flow) control	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6.2 Durability of diverters	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6.3 Durability of thermostat	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.3 Flow rate and sensitivity of temperature control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.5 Mixed water temperature overshoot on operation of diverter (manual or automatic return)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.6 Mixed water temperature overshoot on operation of second outlet	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.7 Mixed water temperature overshoot on starting from ambient temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.8 Mixed water temperature overshoot on adjustment of mixed water temperature	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.9 Thermostat shut-off	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.10 Temperature stability with changing water supply pressure	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.11 Temperature stability with changing water supply temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.12 Temperature stability at reduced flow rate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.0* Designation	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9.0 Marking	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10.0* Installation and operating instructions	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Tests are not conducted under accreditation according to ISO/IEC 17025

Remark:
none

2 Sampling, sample preparation and conditioning

The sampling has not been carried out by Kiwa and is therefore not making part of the ISO/IEC 17025 accreditation.

Preparation, conditioning, test sequence and test set-up of the valves, is in accordance with the requirements of the NHS D08, 2017 edition.

3 Measurement uncertainty of testing in the context of ISO/IEC 17025

The pass/fail decision in this report is made, independently of the measurement uncertainty. Estimated uncertainties for activities carried out under accreditation are available on request.

4 Test results

Article numbers as mentioned below refer to the NHS D08. Results are marked **red**, when not in compliance with the requirements. Results marked with "NPD" when no performance was determined. Results marked with "N/A" when requirements are not applicable.

Where applicable, graphs of the temperature transients are available on request.

5 Leaktightness

- a. Leaktightness of the thermostatic mixing valve upstream of the obturator and of the obturator (article 5.4)**
- sample A
- test pressure (bar) 16
 duration of test (sec.) 60
 test result pass fail NPD N/A
- b. Leaktightness of the obturator of the thermostatic mixing valve: cross flow between hot and cold water (article 5.5)**
- sample A
- cold water side**
 test pressure (bar) 4
 duration of test (sec.) 60
- hot water side**
 test pressure (bar) 4
 duration of test (sec.) 60
 test result pass fail NPD N/A
- c. Leak tightness of the thermostatic mixing valve downstream of the obturator (article 5.6)**
- sample A
- test pressure (bar) 4
 test pressure reduced (bar) 0,2
 duration of test (sec.) 60
 test result pass fail NPD N/A
- d. Leak tightness of the manual diverter of the thermostatic mixing valve (article 5.7)**
- sample A
- static water pressure (bar) 4
 reduced static water pressure (bar) 0,2
 test result pass fail NPD N/A
- e. Leaktightness of the diverter with automatic return of the thermostatic mixing valve (article 5.8)**
- sample A
- static flow pressure (bar) 4
 reduced flow pressure (bar) 0,2
 test result pass fail NPD N/A

6 Durability

- a. Durability of on/off (flow) control (article 6.1)**
- sample A
- hot water temperature (°C) 67,0
 cold water temperature (°C) 14,4
 hot water supply pressure (bar) 1,0
 cold water supply pressure (bar) 1,0
 test result pass fail NPD N/A
- b. Durability of diverters (article 6.2)**
- design: automatic
- sample A
- hot water temperature (°C) 67,0
 cold water temperature (°C) 14,4
 hot water supply pressure (bar) 1,0
 cold water supply pressure (bar) 1,0
 flow rate (l/min) 2
 test result pass fail NPD N/A
- c. Durability of thermostat (article 6.3)**
- sample B
- hot water temperature (°C) 64,5
 cold water temperature (°C) 19,5
 hot water supply pressure (bar) 3
 cold water supply pressure (bar) 3
 flow rate (l/min) 15
 mixed water temperature (°C) 43
 test result pass fail NPD

7 Performance

- a. Flow rate and sensitivity of temperature control (article 7.3)**
- sample A
- hot water temperature (°C) 67,0
 cold water temperature (°C) 14,4
 hot water pressure loss (bar) 1,0
 cold water pressure loss (bar) 1,0
- sample A
- setting 1**
 mixed water temperature (°C) 40,5
 flow rate (l/min) 26,8
 outlet pressure (bar) 2
- setting 2**
 mixed water temperature (°C) 44,7
 flow rate (l/min) 24,4
 outlet pressure (bar) 2
- setting 3**
 mixed water temperature (°C) 47,6
 flow rate (l/min) 22,8
 outlet pressure (bar) 2
- setting 4**

sample A

mixed water temperature (°C)
 flow rate (l/min)
 outlet pressure (bar)

setting 5
 mixed water temperature (°C)
 flow rate (l/min)
 outlet pressure (bar)

Measured sensitivity: 10 (degrees angular/K or mm/K)

test result flow rate pass fail NPD N/A
 test result sensitivity pass fail NPD N/A

b. Initial settings for thermal performance tests (article 7.4)

	sample A	sample B	sample C
hot water temperature (°C)	57 +/- 1	57 +/- 1	57 +/- 1
cold water temperature (°C)	15 +/- 1	15 +/- 1	15 +/- 1
mixed water temperature (°C)	44 +/- 0,2	44 +/- 0,2	44 +/- 0,2
hot water supply pressure (kPa)	3 +/- 0,2	3 +/- 0,2	3 +/- 0,2
cold water supply pressure (bar)	3 +/- 0,2	3 +/- 0,2	3 +/- 0,2
mixed flow rate (l/min)	20 +/- 1	20 +/- 1	20 +/- 1

c. Mixed water temperature overshoot on operation of diverter (manual or automatic return) (article 7.5)

test result pass fail NPD N/A

d. Mixed water temperature overshoot on operation of second outlet (article 7.6)

test result pass fail NPD N/A

e. Mixed water temperature overshoot on starting from ambient (article 7.7)

Sample A art. 7.7 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	56,3	57,0	57,0
cold water temperature (°C)	14,2	14,2	14,4
mixed water temperature (°C)	43,2	43,4	43,3
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,9	20,0	20,0

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	0,53 - 3,00 sec	0,53 - 2,85 sec	0,60 - 2,88 sec	1,73 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,30	0,44 - 2,42 sec	0,38 - 2,32 sec	0,48 - 2,38 sec	1,40 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,00	0,33 - 1,98 sec	0,19 - 1,86 sec	0,34 - 1,92 sec	1,10 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,50	0,15 - 1,49 sec	0 - 1,40 sec	0,09 - 1,42 sec	0,91 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,00	0 - 0,85 sec	0 - 0,82 sec	0,50 sec	0,89 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,20	0 - 0,24 sec	- sec	- sec	0,24 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,50	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		43,3°C	43,4°C	43,3°C				
Maximum temperature		50,4 - 52,2°C	49,8 - 52,2°C	50,3 - 52,2°C				

Sample B art. 7.7 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,5	57,7	57,6
cold water temperature (°C)	14,8	15,2	15,2
mixed water temperature (°C)	43,5	43,5	43,4
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,9	19,9	19,9

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	0,12 - 2,31 sec	0,68 - 2,27 sec	0,63 - 2,09 sec	1,35 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	0 - 1,81 sec	0,59 - 1,81 sec	0,53 - 1,65 sec	1,28 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	0 - 1,40 sec	0,47 - 1,41 sec	0,41 - 1,26 sec	0,99 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	0 - 1,00 sec	0,32 - 1,00 sec	0,23 - 0,82 sec	0,67 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,5	0 - 0,51 sec	0,08 - 0,50 sec	0 - 0,31 sec	0,35 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		44,7°C	44,4°C	44,1°C				
Maximum temperature		47,5 - 52,0°C	51,5 - 52,1°C	50,9 - 51,7°C				

Sample C art. 7.7 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,1	57,2	56,6
cold water temperature (°C)	14,6	14,9	15,2
mixed water temperature (°C)	43,3	43,3	43,4
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,9	19,9	19,9

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	0,70 - 3,10 sec	0,39 - 3,13 sec	0,39 - 3,04 sec	1,79 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	0,62 - 2,35 sec	0,27 - 2,41 sec	0,27 - 2,43 sec	1,39 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	0,51 - 1,80 sec	0,08 - 1,90 sec	0,11 - 1,90 sec	1,78 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	0,37 - 1,36 sec	0 - 1,44 sec	0 - 1,43 sec	1,15 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	0,14 - 0,85 sec	0 - 0,98 sec	0 - 0,94 sec	0,73 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	0 - 0,27 sec	0 - 0,29 sec	0 - 0,28 sec	0,28 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,50	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		43,3°C	43,5°C	43,5°C				
Maximum temperature		51,5 - 42,5°C	49,5 - 52,5°C	49,6 - 52,6°C				

test result pass fail NPD

f. Mixed water temperature overshoot on adjustment of mixed water temperature (article 7.8)

test result pass fail NPD N/A



g. Thermal shut-off (article 7.9)

Sample A art. 7.9 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,4	57,5	57,5
cold water temperature (°C)	15,6	15,7	15,7
mixed water temperature (°C)	43,5	43,6	43,6
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	20,0	20,0	20,0

Cold water isolation

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+1	>10	906,22 sec	2,54 - 961,35 sec	901,63 sec	690,44 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,30	906,16 sec	2,08 - 950,53 sec	901,55 sec	690,08 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,00	905,08 sec	1,75 - 950,49 sec	901,45 sec	689,95 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,50	905,98 sec	1,42 - 950,29 sec	901,35 sec	689,76 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,00	896,07 sec	0,90 - 45,53 - 903,92 sec	891,08 sec	503,90 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,20	20,82 sec	0,50 - 13,99 - 137,00 sec	19,89 sec	38,43 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	11,44 sec	0,47 sec	6,55 sec	6,15 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	- sec	- sec	- sec	- sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Maximum temperature		54,0 °C	53,8 °C	54,2 °C				

Cold water restoration

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+2	>10	1,00 sec	- sec	- sec	1,00 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+3	6,3	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+4	4,0	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	2,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	1,9	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	1,2	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11								
+12								
Restoration temperature		44,2 °C	42,4 °C	44,3 °C				
Maximum temperature		52,2 °C	51,1 °C	52,2 °C				



Hot water isolation

Collection	Test 1	Test 2	Test 3
0 - 5 seconds (min)	75	65	74
5 - 35 seconds (min)	218	215	211
Start temperature	43,7 °C	43,5 °C	43,7 °C
Temperature after 5 sec	43,6 °C	43,3 °C	43,4 °C

Hot water restoration

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	3,00 sec	1,52 sec	3,15 sec	2,56 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	2,40 sec	0,86 sec	2,56 sec	1,95 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	1,94 sec	- sec	2,08 sec	2,01 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	1,50 sec	- sec	1,60 sec	1,55 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,00	0,95 sec	- sec	1,12 sec	1,04 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	0,26 sec	- sec	- sec	0,28 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		44,1 °C	43,9 °C	44,2 °C				
Maximum temperature		52,6 °C	49,5 °C	52,9 °C				



Sample B art. 7.9 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	56,6	56,6	57,5
cold water temperature (°C)	15,1	15,0	14,8
mixed water temperature (°C)	43,4	43,4	43,2
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,8	19,8	19,9

Cold water isolation

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+1	>10	902,43 sec	958,48 sec	902,51 sec	921,14 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	187,46 - 646,00 sec	202,09 - 60,00 - 534,00 sec	163,92 - 500,00 sec	343,35 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	91,00 - 144,00 - 265,00 - 51,00 sec	82,09 - 533,00 sec	94,92 - 453,00 sec	195,89 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	50,00 - 155,00 - 42,00 sec	50,09 - 170,00 sec	63,92 sec	88,67 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	30,00 sec	37,09 sec	50,92 sec	39,34 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	20,00 sec	30,09 sec	33,92 sec	28,00 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	5,00 sec	12,09 sec	13,92 - 6,00 sec	9,25 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	2,00 sec	6,09 sec	3,92 sec	4,00 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Maximum temperature		54,4 °C	54,7 °C	54,9 °C				



Cold water restoration

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	bespreken sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		43,2 °C	43,3 °C	43,3 °C				
Maximum temperature		52,0 °C	51,0 °C	51,5 °C				

Hot water isolation

Collection	Test 1	Test 2	Test 3
0 - 5 seconds (min)	245	131	99
5 - 35 seconds (min)	385	153	91
Start temperature	43,4 °C	43,2 °C	43,4 °C
Temperature after 5 sec	42,2 °C	43,1 °C	43,3 °C

Hot water restoration

Temp.	limits	Test 1 results	Test 2 results	Test 3 results	Average results	pass	fail	N/A
+4	>10	- sec	2,10 sec	2,18 sec	2,14 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	- sec	1,58 sec	1,68 sec	1,62 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	- sec	1,14 sec	1,24 sec	1,19 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	- sec	0,72 sec	0,80 sec	0,76 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	- sec	0,15 sec	0,41 sec	0,28 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		43,9 °C	44,1 °C	44,1 °C				
Maximum temperature		44,8 °C	51,4 °C	51,7 °C				

Sample C art. 7.9 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	56,9	56,7	57,1
cold water temperature (°C)	15,0	14,8	14,7
mixed water temperature (°C)	43,3	43,3	43,3
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,9	19,6	19,9

Cold water isolation

Temp.	limits	Test 1	Test 2	Test 3	Average	pass	fail	N/A
		results	results	results				
+4	>10	6,63 - 195,60 sec	901,54 sec	899,82 sec	675,40 sec	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	6,36 - 14,45 - 487,04 sec	265,38 sec	276,19 sec	205,88 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	6,12 - 14,26 - 49,98 sec	67,61 sec	99,82 - 12,50 - 3,40	27,20 sec	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
+7	2,5	5,90 - 14,05 - 13,85 sec	47,53 sec	43,14 sec	24,90 sec	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
+8	1,6	0,63 - 4,85 - 13,84 - 4,39 sec	0,26 - 24,53 sec	31,91 sec	11,44 sec	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
+9	1,2	0 - 4,23 - 4,04 - 2,71	9,29 sec	6,22 - 9,71 sec	6,03 sec	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Maximum temperature		52,9 °C	53,2 °C	53,2 °C				

Cold water restoration

Temp.	limits	Test 1	Test 2	Test 3	Average	pass	fail	N/A
		results	results	results				
+4	>10	sec	0,66 sec	0,62 sec	0,61 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	sec	0,07 sec	0,13 sec	0,10 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		43,1 °C	43,5 °C	43,4 °C				
Maximum temperature		48,0 °C	49,3 °C	49,3 °C				

Hot water isolation

Collection	Test 1	Test 2	Test 3
0 - 5 seconds (m)	35	38	33
5 - 35 seconds (m)	17	8	7
Start temperature	43,8 °C	43,8 °C	43,4 °C
Temperature after 8 sec.	43,0 °C	42,7 °C	42,2 °C

Hot water restoration

Temp.	limits	Test 1	Test 2	Test 3	Average	pass	fail	N/A
		results	results	results				
+4	>10	3,49 sec	3,53 sec	3,46 sec	3,48 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+5	6,3	2,97 sec	2,97 sec	2,88 sec	2,93 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+6	4,0	2,36 sec	2,46 sec	2,29 sec	2,37 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+7	2,5	1,90 sec	1,99 sec	1,82 sec	1,90 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+8	1,9	1,44 sec	1,55 sec	1,30 sec	1,43 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+9	1,2	0,85 sec	0,96 sec	0,62 sec	0,81 sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+10	0,75	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+11	0,5	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+12	0,25	sec	sec	sec	sec	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Restoration temperature		42,9 °C	43,5 °C	43,5 °C				
Maximum temperature		53,0 °C	53,2 °C	52,6 °C				

test result pass fail NPD

h. Temperature stability with changing water supply pressure (article 7.10)
Sample A art. 7.10 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,3	57,2	57,2
cold water temperature (°C)	15,0	15,2	15,4
mixed water temperature (°C)	43,4	43,7	43,5
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	6,7	6,7	6,7

Cold water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.			
1	300	200	50,0	300	200	50,3	300	200	50,4	50,2	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	300	100	48,5	300	100	49,3	300	100	48,9	48,9	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3	300	50	48,5	300	50	49,3	300	50	49,2	49,0	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	300	300	42,9	300	300	43,6	300	300	43,6	43,4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	300	500	40,6	300	500	41,0	300	500	41,1	40,9	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	300	300	43,4	300	300	44,1	300	300	44,0	43,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Hot water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.			
1	200	300	42,4	200	300	43,0	200	300	43,5	43,0	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	100	300	40,9	100	300	41,5	100	300	41,5	41,3	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3	50	300	41,8	50	300	42,2	50	300	42,3	42,3	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	300	300	43,5	300	300	44,2	300	300	44,2	44,0	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	500	300	50,2	500	300	50,7	500	300	50,5	50,5	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	300	300	42,8	300	300	43,5	300	300	43,4	43,2	<input type="checkbox"/>	<input checked="" type="checkbox"/>

* Great fluctuation of the temperature, the average temperature is noted

Sample B art. 7.10 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,1	57,4	57,5
cold water temperature (°C)	15,1	14,8	15,1
mixed water temperature (°C)	43,5	43,3	43,2
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	20,0	20,0	20,0

Cold water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.			
1	300	200	46,8	300	200	49,6	300	200	49,9	48,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	300	100	50,4	300	100	51,1	300	100	52,0	51,2	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3	300	50	51,0	300	50	51,6	300	50	52,7	51,6	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	300	300	42,6	300	300	42,6	300	300	43,4	42,7	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	300	500	41,8	300	500	42,5	300	500	43,0	42,4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	300	300	43,5	300	300	44,1	300	300	44,6	44,1	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Hot water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.			
1	200	300	42,4	200	300	43,0	200	300	43,5	43,0	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	100	300	41,2	100	300	41,8	100	300	42,2	41,7	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3	50	300	41,4	50	300	41,8	50	300	42,3	41,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	300	300	43,9	300	300	44,4	300	300	44,9	44,4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	500	300	49,4	500	300	50,0	500	300	50,0	49,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	300	300	42,0	300	300	42,6	300	300	43,2	42,6	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Sample C art. 7.10 HP-T44

Initial settings	Test 1	Test 2	Test 3
hot water temperature (°C)	57,1	57,0	57,2
cold water temperature (°C)	14,8	14,8	15,1
mixed water temperature (°C)	43,4	43,3	43,5
hot water supply pressure (kPa)	300	300	300
cold water supply pressure (kPa)	300	300	300
flow rate (l/min)	19,8	19,9	19,9

Cold water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.	Press. hot	Press. cold	Mixed temp.			
1	300	200	49,5	300	200	47,4	300	200	46,5	47,6	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	300	100	48,3	300	100	46,9	300	100	47,6	47,6	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3	300	50	48,3	300	50	47,4	300	50	47,8	47,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	300	300	44,6	300	300	44,4	300	300	43,3	43,8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	300	500	45,0	300	500	44,0	300	500	43,8	44,3	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	300	300	44,9	300	300	43,7	300	300	43,8	44,1	<input type="checkbox"/>	<input checked="" type="checkbox"/>



Hot water pressure changes

Change	Test 1			Test 2			Test 3			Av. mixed temp.	pass	fail
	Press. hot	Press. cold	mixed temp.	Press. hot	Press. cold	mixed temp.	Press. hot	Press. cold	mixed temp.			
1	200	300	45,0	200	300	44,0	200	300	44,3	44,4	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2	100	300	44,8	100	300	44,1	100	300	43,6	44,2	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3	50	300	43,9	50	300	42,9	50	300	42,8	43,2	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4	300	300	44,9	300	300	43,9	300	300	44,1	44,3	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5	500	300	48,3	500	300	47,7	500	300	47,7	47,9	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6	300	300	44,5	300	300	43,4	300	300	43,3	43,7	<input checked="" type="checkbox"/>	<input type="checkbox"/>

test result pass fail NPD

i. Temperature stability with changing water supply temperature (article 7.11)

Sample A art. 7.11 HP-T44

Initial settings
hot water supply pressure (kPa) 300
cold water supply pressure (kPa) 300
mixed flow rate (l/min) 20,0

	hot temp.	cold temp.	mixed temp.
Initial	57,3 °C	15,2 °C	43,9 °C
1 st change	56,9 °C	7,4 °C	43,5 °C
2 nd change	57,1 °C	20,7 °C	44,5 °C
3 rd change	57,4 °C	15,5 °C	43,8 °C
Initial	57,3 °C	15,5 °C	43,8 °C
1 st change	52,5 °C	15,4 °C	44,2 °C
2 nd change	64,7 °C	15,4 °C	43,9 °C
3 rd change	57,4 °C	15,5 °C	43,7 °C

Sample B art. 7.11 HP-T44

Initial settings
hot water supply pressure (kPa) 300
cold water supply pressure (kPa) 300
mixed flow rate (l/min) 19,9

	hot temp.	cold temp.	mixed temp.
Initial	57,1 °C	15,0 °C	43,0 °C
1 st change	56,4 °C	7,2 °C	42,9 °C
2 nd change	57,7 °C	20,4 °C	43,4 °C
3 rd change	57,3 °C	14,7 °C	43,3 °C
Initial	57,1 °C	14,8 °C	43,3 °C
1 st change	52,7 °C	15,1 °C	43,2 °C
2 nd change	64,5 °C	15,0 °C	43,9 °C
3 rd change	57,1 °C	15,0 °C	43,0 °C



Sample C art. 7.11 HP-T44

Initial settings
hot water supply pressure (kPa) 300
cold water supply pressure (kPa) 300
mixed flow rate (l/min) 19,9

	hot temp.	cold temp.	mixed temp.
Initial	57,1 °C	14,8 °C	43,3 °C
1 st change	56,6 °C	7,5 °C	42,9 °C
2 nd change	57,8 °C	20,2 °C	42,4 °C
3 rd change	57,4 °C	14,7 °C	42,2 °C
Initial	57,2 °C	14,7 °C	42,3 °C
1 st change	52,5 °C	15,0 °C	43,4 °C
2 nd change	64,4 °C	15,0 °C	41,8 °C
3 rd change	56,9 °C	15,0 °C	42,1 °C

test result pass fail NPD

j. Temperature stability at reduced flow rate (article 7.12)

Sample A art. 7.12 HP-T44

Initial settings
hot water temperature (°C) 57,1
cold water temperature (°C) 15,2

	Test 1			Test 2			Test 3			Av. mixed temp.			
	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate				
Initial	300	300	20,2	43,4	300	300	20,0	43,5	300	300	20,1	43,4	43,4
hot press. red.	300	250	19,5	48,5	300	250	19,3	48,5	300	250	19,3	46,7	46,8
low red.	300	250	10,1	47,8	300	250	10,0	47,4	300	250	10,0	47,4	47,5
reinstoration	300	300	20,0	43,4	300	300	20,0	43,2	300	300	20,0	43,3	43,3
Initial	300	300	20,1	43,4	300	300	20,0	43,3	300	300	20,0	43,3	43,3
hot press. red.	250	300	18,3	49,5	250	300	18,2	42,5	250	300	18,3	42,5	42,5
low red.	250	300	10,0	42,2	250	300	10,0	42,2	250	300	10,0	42,4	42,3
reinstoration	300	300	20,0	43,7	300	300	20,0	43,7	300	300	20,0	43,8	43,7



Sample B art. 7.12 HP-T44

Initial settings
hot water temperature (°C) 56,6
cold water temperature (°C) 15,0

	Test 1			Test 2			Test 3			Av. mixed temp.			
	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate				
Initial	300	300	19,8	43,3	300	300	19,8	43,0	300	300	19,9	43,2	43,2
hot press. red.	300	250	19,2	48,7	300	250	19,1	48,3	300	250	19,2	46,7	46,9
low red.	300	250	10,2	45,4	300	250	10,0	45,4	300	250	10,0	45,0	45,0
reinstoration	300	300	20,0	42,9	300	300	19,8	42,8	300	300	19,9	43,0	42,9
Initial	300	300	20,0	43,0	300	300	19,9	42,8	300	300	20,0	43,0	42,9
hot press. red.	250	300	18,2	42,7	250	300	18,1	42,8	250	300	18,2	42,4	42,6
low red.	250	300	10,1	43,8	250	300	10,1	43,9	250	300	10,0	44,2	44,0
reinstoration	300	300	20,0	43,5	300	300	20,0	43,3	300	300	20,0	43,6	43,5

Sample C art. 7.12 HP-S

Initial settings
hot water temperature (°C) 56,9
cold water temperature (°C) 14,9

	Test 1			Test 2			Test 3			Av. mixed temp.			
	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate	hot press.	cold press.	mixed flow rate				
Initial	300	300	19,8	43,5	300	300	20,0	43,4	300	300	20,0	43,4	43,5
hot press. red.	300	250	19,2	48,4	300	250	18,4	48,4	300	250	19,3	48,5	48,5
low red.	300	250	10,0	47,8	300	250	10,0	48,5	300	250	10,0	46,0	47,4
reinstoration	300	300	19,9	43,3	300	300	19,8	43,5	300	300	20,0	43,3	43,4
Initial	300	300	19,9	43,3	300	300	19,9	43,4	300	300	20,0	43,8	43,5
hot press. red.	250	300	18,2	42,8	250	300	18,1	43,8	250	300	18,2	43,5	43,4
low red.	250	300	10,1	42,9	250	300	10,1	44,6	250	300	10,0	43,9	43,8
reinstoration	300	300	19,9	43,9	300	300	20,0	44,0	300	300	20,0	43,8	43,9

test result pass fail NPD

8 Marking (article 9)

The thermostatic mixing valves have been provided with the following marks:

Requirement	Yes	No	Marking applied
Manufacturers name or identification	<input type="checkbox"/>	<input type="checkbox"/>	
location	<input type="checkbox"/>	<input type="checkbox"/>	
special tool needed to remove detachable part of the valve	<input type="checkbox"/>	<input type="checkbox"/>	N/A
unique model reference	<input type="checkbox"/>	<input type="checkbox"/>	
Remark			
test result	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input checked="" type="checkbox"/> NPD <input type="checkbox"/> N/A



9 Installation and operating instructions (article 10)

The provided installation, operating and maintenance instructions include:

- information on the designation of the thermostatic mixing valve concerned Yes No
- information on the commissioning and routine in-service tests to be performed Yes No
- information on the frequency of in-service tests and service work Yes No
- information on the need for any anti-backsiphonage devices (e.g. check valves) required to be installed with the mixing valve together with the specification of such devices Yes No
- the need for the inclusion of any isolating valves etc. to enable on site tests to be made Yes No
- details of suitable outlet fittings (e.g. draw-off taps etc.) Yes No

test result pass fail NPD N/A

10 Remarks

none

11 Equipment used

The equipment as has been used during the various tests has been included in the accredited calibration system.

12 Summary of failures

Article of NBS DOB	Subject	Article of test report	Page of test report
Art.7.9	Thermal shut-off	7.g	10
Art.7.10	Temperature stability with changing water supply pressure	7.h	16
Art.7.12	Temperature stability at reduced flow	7.j	19

Page 22 of 22

Order number: XXXXXX

Kiwa report number: XXXXX-TR-rev0



Appendix A – Picture of the tested sample



International accredited testing
laboratory in accordance with
EN ISO/IEC 17025
www.rva.nl

The RvA is participant in ILAC MRA

Kiwa Nederland BV

Sir W. Churchilllaan 273 - P.O. Box 70 - 2280 AB Rijswijk - The Netherlands
Telephone: +31 (0)88 998 4400 - Telefax: +31 88 998 4420 - www.kiwa.nl

----- END OF REPORT -----